# 30mm Hazardous Location Switches: EU2B Series





# **STANDARDS COMPLIANCE**

	Switches	Pilot Lights	Meters
UL	Class I, Zone 1, AEx de IIC T6 Gb	Class I, Zone 1, AEx de IIC T6 Gb	Class I, Zone 1, AEx de IIC T6 Gb
	Class I, Div 2, Groups A, B, C and D	Class I, Div 2, Groups A, B, C and D	Class I, Div 2, Groups A, B, C and D
c-UL	Class I, Zone 1, Ex de IIC T6 Gb	Class I, Zone 1, Ex de IIB T6 Gb	Class I, Zone 1, Ex de IIC T6 Gb
	Class I, Div 2, Groups A, B, C and D	Class I, Div 2, Groups C and D	Class I, Div 2, Groups A, B, C and D
ATEX	EX EXII2G Ex de IIC		€ƏII2G Ex de IIC Gb €ƏII2D Ex tb IIIC Db IP65

# **CERTIFICATE NUMBERS**

UL/cUL	E347230
ATEX	PTB 08 ATEX 1053 U PTB 08 ATEX 1003 U

# **APPLICABLE STANDARDS**

Products	Applicable Standards	Mark	Certifications
Pushbuttons Selector Switches Key Selector Switches Pilot Lights	EN60947-5-1	CE	EU Low Voltage Directive
Ference on Star Curitakan			TÜV SÜD
Emergency Stop Switches	EN60947-5-5	CE	EU Low Voltage Directive

# **PRODUCT DESCRIPTION**

Complying with UL and ATEX Directives for hazardous environments, new 30mm EU2B Hazardous Location Switches provide increased safety for your applications.

Available models include:

- Pushbuttons
- Pilot Lights
- Selector Switches
- Key Selector Switches
- Emergency Stop Switches
- Meters

# **KEY FEATURES**

- Class I, Zone 1/Division 2
- Applicable in explosive gas atmospheres (AEx de IIC T6 Gb)
- UL Type 4X rated
- Up to 3 contact blocks
- Selector switches available with lever or key
- Selector switches available with overlapping contacts
- Exposed and finger-safe (IP20) screw terminals available



# **SPECIFICATIONS**

#### **General Specifications**

Degree of Protection	IP65 (IEC60529), Type	IP65 (IEC60529), Type 4X				
Insulation Resistance	100 MΩ minimum (50	100 MΩ minimum (500V DC megger)				
Operating Temperature	-20 to +50°C (no free	ezing)				
Operating Humidity	45 to 85% (no conde	nsation)				
Altitude	2,000m Maximum					
Pollution Degree	3					
Shock Resistance	Operating Extremes	100-m/s <sup>2</sup> Emergency Stop Switch: 150-m/s <sup>2</sup> (without Meter)				
	Damage Limits	1000-m/s <sup>2</sup>				
Vibration Resistance	Operating Extremes	5 to 55-Hz, amplitude 0.5 mm Emergency Stop Switch: 5 to 500-Hz, amplitude 0.35-mm, acceleration 50-m/s <sup>2</sup> (without Meter)				
vioration nesistance	Damage Limits	30Hz, amplitude 1.5-mm Emergency Stop Switch: 5 to 500-Hz, amplitude 0.35-mm, acceleration 50-m/s <sup>2</sup>				

#### **Contact Rating (Switches)**

Rated Insulation Voltage (Ui)		600V					
Rated Thermal Current (Ith)			10A*				
Rated Operating	lated Operating Voltage (Ue)		24V	120V	240V	500V	
	AC 50/60Hz	Resistive Load (AC12)	10A*	10A*	6A	2.8A	
Rated Operat-		Inductive Load (AC15)	10A*	6A	3A	1.4A	
ing Current (Ie)	DC	Resistive Load (DC12)	8A	2.2A	1.1A	—	
lr Ir		Inductive Load (DC13)	4A	1.1A	0.55A	—	
Note: Up to 2 contacts (per control unit): 10A							

3 contacts (per control unit): 9A

Minimum applicable load: 3V AC/DC, 5mA

Applicable operating locations may vary according to operating conditions and load types.

Contact Bating	Rating Test Code Current		Maximum current, Amperes							Maxir Volt-Ar	
Code			Volt	240	Volt	480	Volt	600	Volt	600	Volt
Designation	Amperes	Make	Break	Make	Break	Make	Break	Make	Break	Make	Break
A600	10	60	6.00	30	3.00	15	1.5	12	1.2	7200	720

#### Switches

Rated Insulation Volta	ige	600V		
Contact Resistance		50mΩ maximum (initial value)		
Impulse Withstand Vo	oltage (Uimp)	6kV		
Insulation Resistance		100MΩ minimum (500V DC megger)		
Short-Circuit Protecti	on	250V/10A fuse (Type aM IEC60269-1/IEC60269-2)		
Conditional Short-Cire	cuit Current	1,000A		
	Pushbutton	1,000,000 operations minimum		
Mechanical Life	Selector Switch	500,000 operations minimum		
Mechanical Life	Key Selector Switch	500,000 operations minimum		
	Emergency Stop Switch	50,000 operations minimum		
	Pushbutton	250,000 (switching frequency 1800 operations/h)		
Flectrical Life	Selector Switch	250,000 (switching frequency 900 operations/h)		
Electrical Life	Key Selector Switch	250,000 (switching frequency 900 operations/h)		
	Emergency Stop Switch	50,000 (switching frequency 900 operations/h)		
Minimum Operator Stroke Required for Direct Opening Action	Emergency Stop Switch	7.0mm		
Maximum Operator Stroke	Emergency Stop Switch	9.0mm		

Note: Contacts will bounce during operation of pushbuttons and selector switches (reference value: 20-ms). Be sure to take contact bounce time into consideration when designing a control circuit.

# **Pilot Lights**

Rated Insulation Voltage (Ui)		500V
Poted Operating Veltage (Up)	Voltage	6V, 12V, 24V AC/DC
Rated Operating Voltage (Ue)	Transformer	120V, 230V, 240V, 380V, 480V AC
Impulse Withstand Voltage (Uimp)		4kV
Insulation Resistance		100 MΩ minimum (500V DC)
Frequency		50/60Hz
Power Concumption (opprov.)	Full Voltage	0.3W
Power Consumption (approx.)	Transformer	1.5VA
Life (reference value)		Approx. 40,000 hours

Note: Because the built-in LED lamp is a high-brightness version, the lamp may light dimly due to induction even when power is off.

#### Meters

Accuracy Class		2.5
Insulation Resistance		100 MΩ minimum (500V DC megger)
	Rated Insulation Voltage (Ui)	300V
er	Operation	Moving core
Jet	Impulse Withstand Voltage (Uimp)	4kV
ammeter	Power Consumption	1VA
a	Measurement	5A, 10A, 30A, 50A, etc
AC	Input (CT Ratio)	1A, 5A
	Extended Memory	3 times, etc
_	Rated Insulation Voltage (Ui)	150V
ammeter	Operation	Moving coil
Ĕ	Impulse Withstand Voltage (Uimp)	2.5kV
am	Input	0 to10V DC, 4 to 20mA, etc.
2	Power Consumption	0.15W
-	Consumption Current	1mA

Note: Use a commercially available CT (current transformer) for all AC ammeters, and install the CT in a non-hazardous location.

# PART NUMBERS

#### Pushbuttons



#### Part Number Structure

EU2B - YB1 11 F S D Operator (style / function) Button color							
B1 : Flush pushbutton / Momentary	Contact arran	gement	Blank: Red. Green, Black.				
B2 : Extended pushbutton / Momentary B3 : Mushroom pushbutton / Momentary	10 : 1N0 20 : 2N0 30 : 3N0	01 : 1NC 02 : 2NC 03 : 3NC	and White included Y : Yellow S : Blue —Terminals				
	11 : 1NO-1NC 21 : 2NO-1NC	12 : 1NO-2NC	F : Finger-safe terminal (IP20) C : Exposed screw terminal				

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Style and Function	Contact Arrangement	Weight (Approx.)	① Button Color
EU2B-YB110@①-D		1N0	60.4	
EU2B-YB101@①-D		1NC	68g	
EU2B-YB111@1-D		1NO-1NC	92g	
EU2B-YB120@①-D		2N0		① Blank - supplied with red, green, black, and white
EU2B-YB102@1-D	Flush Momentary	2NC		buttons
EU2B-YB121@①-D	inomonical y	2NO-1NC		For yellow or blue buttons, specify Y (yellow) or S
EU2B-YB112@1-D		1NO-2NC		(blue).
EU2B-YB130@1-D		3N0	116g	
EU2B-YB103@10-D		3NC		
EU2B-YB210@10-D		1N0		
EU2B-YB201@10-D		1NC	70g	Specify a button color code in place of ① in the part
EU2B-YB211@①-D		1NO-1NC	94g	
EU2B-YB220@10-D		2N0		
EU2B-YB202@10-D	Extended Momentary	2NC		
EU2B-YB221@10-D		2NO-1NC		
EU2B-YB212@①-D		1NO-2NC	118g	
EU2B-YB230@1-D		3N0		number
EU2B-YB203@10-D		3NC		B : black G : green
EU2B-YB310@1-D		1N0	76g	R : red
EU2B-YB301@①-D		1NC	709	S : blue W : white
EU2B-YB311@①-D		1NO-1NC		Y : yellow
EU2B-YB320@1-D		2N0	101g	
EU2B-YB302@①-D	Mushroom Momentary	2NC		
EU2B-YB321@①-D	,	2NO-1NC		
EU2B-YB312@①-D		1NO-2NC	125g	
EU2B-YB330@①-D		3N0	izəy	
EU2B-YB303@①-D		3NC		

Note: ① Button Color.

Specify a contact terminal style in place of  $\circledast$  in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

#### **Emergency Stop Switches**



**Part Number Structure** 

# EU2B - YBV3 11 F R

		-
Operator (style / function)	Contact arrangement	Button color
BV3 : 40mm mushroom/push, pull or twist		R : Red
release	11 : 1NO-1NC 02 : 2NC	Terminals
	03 : 3NC	F : Finger-safe terminal (IP20)
	12 : 1NO-2NC	C : Exposed screw terminal

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Operator	Contact Arrangement	Weight (Approx.)	Button Color	
EU2B-YBV301@R		1NC	96g		
EU2B-YBV311@R		1NO-1NC	120~	R : Red	
EU2B-YBV302@R	ø40 Mushroom	2NC	120g		
EU2B-YBV312@R		1NO-2NC	144-		
EU2B-YBV303@R		3NC	144g		

Specify a terminal style in place of  $\circledast$  in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

#### **Pilot Lights**



#### Part Number Structure

	EU2B - Y <u>L1</u> 2	2 <u>2 F</u> D <u>R</u>	
<b>Operator (s</b> L1 : Pilot Lig	tyle / function) ht / dome	R : Re	
Operating voltage		· <u>Y : Ye</u>	ellow PW:White S:Blue
126 : AC 120V (Transformer type)	66 : AC/DC 6V (Full	voltage type) I	—Terminals
246 : AC 240V (Transformer type)	11 : AC/DC 12V (Full	voltage type)	F : Finger-safe terminal (IP20)
386 : AC 380V (Transformer type) 486 : AC 480V (Transformer type)	22 : AC/DC 24V (Ful	voltage type)	C : Exposed screw terminal

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Туре	Operating Voltage	Weight (Approx.)	① Illumination Color Code		
EU2B-YL1126@D①		120V AC				
EU2B-YL1236@D1		230V AC	150g	R : red G : green A : amber Y : yellow PW : white S : blue		
EU2B-YL1246@D1	Transformer	240V AC				
EU2B-YL1386@D1		380V AC				
EU2B-YL1486@D1		480V AC				
EU2B-YL166@D1		6V AC/DC				
EU2B-YL111@D①	Full Voltage	12V AC/DC	108g			
EU2B-YL122@D1		24V AC/DC				

Note: ① Illumination Color.

Specify a contact terminal style in place of  $\circledast$  in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

-11

## **Selector Switches**



#### Part Number Structure


	EU2B - Y <u>S 2 11 N</u> 1	1 <u>F</u>		
<b>Operator (style / function)</b> S : Selector (Knob operator)		Contact arrang	jement 03 : 3NC	
Number of Positions / Spring Return Actio 2 : 2-position / Maintained	3 : 3-position / Maintained	11:1NO-1NC 0		<b>Terminals</b> F : Finger-safe terminal (IP20)
2R : 2-position / Maintained (Overlap) 2J : 2-position / Maintained (Special function)		30 : 3NO 1 20 : 2NO	2 : 1NO-2NC	C : Exposed screw terminal — Circuit Number Plank : No Designation
21 : 2-position / Spring return from right	33 : 3-position / Spring return two-way			Blank : No Designation N* : See charts

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

#### **2-Position Selector Switches**

		Operator Pos	ition	Maintained	Spring Return from Right	
Contact	Mounting	Ľ	R	LR	L R	Weight (approx)
NO	1		•	EU2B-YS210④	EU2B-YS2110④	74g
NC	3	•		EU2B-YS201④	EU2B-YS2101④	
N0 N0	1		•	EU2B-YS220@	EU2B-YS2120@	
NC	1	•	•	EU2B-YS202@	EU2B-YS2102④	98g
NC NO	3 1	•	•	EU2B-YS211④	EU2B-YS2111④	
NC NO NO	3 1 2	•	•	EU2B-YS230④	EU2B-YS2130④	
NO NC NC	3 1 2	•	•	EU2B-YS203④	EU2B-YS2103④	
NC NO NO	3 1 2	•	•	EU2B-YS221@	EU2B-YS2121@	122g
NC NO	3	•	•			
NC NC NO	2 3 1	•		EU2B-YS212④	EU2B-YS2112④	
NC	2			EU2B-YS2R11@	N/A	98g

Specify a terminal style in place of  $\circledast$  in the part number: F (Finger-safe terminal), C (Exposed screw terminal)




#### 2-Position Selector Switches (Inverse Cam)

		Operator	Position	Maintained				
Contact	Mounting	×	R	L R	Weight (approx)			
NO	1	•		EU2B-YS2J10@	74g			
NC	3		•	EU2B-YS2J01@	3			
NO NO	1 3	•		EU2B-YS2J20④				
NC NC	1		•	EU2B-YS2J02④	98g			
NO	1	•		EU2B-YS2J11④				
NO NO NO	1 2 3	•		EU2B-YS2J30④				
NC NC NC	1 2 3		•	EU2B-YS2J03④				
NO NO NO	1 2 3	•		EU2B-YS2J21④	122g			
NO NC NC	1 2 3	٠	•	EU2B-YS2J12④				

# **3-Position Selector Switches**

		Op	erator Posi	tion	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two Way	
Contact	Mounting	×	C ▲	R	LCR				Weight (approx)
N0 N0	1	•		•	EU2B-YS320@	EU2B-YS3120④	EU2B-YS3220④	EU2B-YS3320④	
NO	2	•		•	EU2B-YS320N1④	EU2B-YS3120N1④	EU2B-YS3220N1④	EU2B-YS3320N1@	
NC	1				EU2B-YS302④	EU2B-YS302@	EU2B-YS3202④	EU2B-YS3302④	
NC NC	2		•		EU2B-YS302N1@	EU2B-YS3102N1@3	EU2B-YS3202N1@3	EU2B-YS3302N1④	
N0 NC	1	•			EU2B-YS311@	EU2B-Y\$311@	EU2B-YS3211④	EU2B-YS3311@	98g
NC NO	1 3			•	EU2B-YS311N1@	EU2B-YS3111N1④	EU2B-YS3211N1④	EU2B-YS3311N1④	
NO NC	1 2	•	•		EU2B-YS311N2@	EU2B-YS3111N2④	EU2B-YS3211N2④	EU2B-YS3311N2④	
NC NO	2 3		•	•	EU2B-YS311N3④	EU2B-YS3111N3①	EU2B-YS3211N3①	EU2B-YS3311N3①	
NO NC	2 3	•		٠	EU2B-YS311N4@	EU2B-YS3111N4④	EU2B-YS3211N4④	EU2B-YS3311N4④	
NO NO NO	1 2 3	•		•	EU2B-Y\$330@	EU2B-Y\$3130@	EU2B-YS3230④	EU2B-YS3330④	
NC NC	1 2		-	-	EU2B-YS303④	EU2B-YS3103④	EU2B-YS3203④	EU2B-YS3303④	
NC NO	3 1	•	•						122g
NC NO	2 3		•	•	EU2B-YS3 21N1④	EU2B-YS3121N1④	EU2B-YS3221N1④	EU2B-YS3321N1④	
NC NO NC	1 2 3	•		•	EU2B-YS3 12N1④	EU2B-YS3112N1④	EU2B-YS3212N1④	EU2B-YS3312N1④	

Specify a terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal)



#### **Key Selector Switches**



#### Part Number Structure

#### EU2B - YSK 2 11 N1 F A

Operator (style / function) SK: Key selector (Key operator)		Contact arrai	ngement 03 : 3NC	Key Removable Position See Key removable option codes below
Number of Positions / Spring Return Acti 2 : 2-position / Maintained 2R : 2-position / Maintained (Overlap) 2J : 2-position / Maintained (Special function 21 : 2-position / Spring return from right	3: 3 -position / Maintained 31 : 3-position / Spring return from right	11 : 1NO-1NC 01 : 1NC		└── <b>Terminals</b> F : Finger-safe terminal (IP20) C : Exposed screw terminal ── <b>Circuit Number</b> Blank : No Designation N <sup>+</sup> : See the following charts

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

#### **2-Position Key Selector Switches**

		Operator Position	Maintained	Spring Return from Right	
Contact	Mounting	L R	L R		Weight (approx)
NO	1	•	EU2B-YSK210@3	EU2B-YSK2110@3	96g
NC	3	•	EU2B-YSK201@3	EU2B-YSK2101@3	309
N0 N0	1 3	•	EU2B-YSK220@3	EU2B-YSK2120@3	
NC NC	1	•	EU2B-YSK202@3	EU2B-YSK2102@3	120g
NO NC	1	•	EU2B-YSK211@3	EU2B-YSK2111@3	
N0 N0 N0	1 2 3	•	EU2B-YSK230@3	EU2B-YSK2130@3	
NC NC NC	1 2 3	•	EU2B-YSK203@3	EU2B-YSK2103@3	144g
NO NO NC	1 2 3	•	EU2B-YSK221@3	EU2B-YSK2121@3	144 <u>y</u>
NO NC NC	1 2 3	•	EU2B-YSK212@3	EU2B-YSK2112@3	
NO NC	1 2		EU2B-YSK2R11@3	N/A	120g

Key is removable in all maintained positions. Specify key removal position in place of  $\circledast$  in the part number. See table.

Specify a terminal style in place of  $\circledast$  in the part number: F (Finger-safe terminal), C (Exposed screw terminal).

Operator Position

R Contact Block Position Contact Block 1 Contact Block 2 Contact Block 2 Contact Block 3

The key can be released in any maintained position.

		Operator	erator Position Maintained		
Contact	Mounting	×	R	L R	Weight (approx)
NO	1	•		EU2B-YSK2J10@3	96g
NC	3		•	EU2B-YSK2J01@3	009
NO NO	1 3	•		EU2B-YSK2J20@3	
NC NC	1		•	EU2B-YSK2J02@3	120g
NO NC	1 3	•	•	EU2B-YSK2J11®3	
NO NO NO	1 2 3	•		EU2B-YSK2J30@3	
NC NC NC	1 2 3		•	EU2B-YSK2J03@3	144
NO NO NC	1 2 3	•	•	EU2B-YSK2J21@3	144g
NO NC NC	1 2 3	•	•	EU2B-YSK2J12@3	

# 2-Position Key Selector Switches (Inverse Cam)

# **③ Key Removable Option Codes (2-position)**


Code	Description
А	Key removable in any position
В	Key removable in left position
С	Key removable in right position

#### **3-Position Key Selector Switches**

		Of	perator Posi	tion	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two Way	
Contact	Mounting	L K	C ▲	R	L C R		L C R		Weight (approx)
NO	1	•							
NO	3			•	EU2B-YSK320@3	EU2B-YSK3120@3	EU2B-YSK3220@3	EU2B-YSK3320@3	
NO	2	•		•	EU2B-YSK320N1@3	EU2B-YSK3120N1@3	EU2B-YSK3220N1@3	EU2B-YSK3320N1@3	
NO	3			•					
NC	1				EU2B-YSK302@3	EU2B-YSK302@3	EU2B-YSK3202@3	EU2B-YSK3302@3	
NC	3				EUZD-13K3UZ@/3	EU2D-13N3U2@3	EU2D-13K32U2@3	EUZD-13K33UZ@3	
NC	2		•		EU2B-YSK302N1@3	EU2B-YSK3102N1@3	EU2B-YSK3202N1@3	EU2B-YSK3302N1@3	
NC	3								
NO	1	•			EU2B-YSK311@3	EU2B-YSK311@3	EU2B-YSK3211@3	EU2B-YSK3311@3	120g
NC	3								
NC	1				EU2B-YSK311N1@3	EU2B-YSK3111N1@3	EU2B-YSK3211N1@3	EU2B-YSK3311N1@3	
NO	3			•					
NO	1	•							
NC	2		•		EU2B-YSK311N2@3	EU2B-YSK3111N2@3	EU2B-YSK3211N2@3	EU2B-YSK3311N2@3	
NC	2		•		EU2B-YSK311N3@3	EU2B-YSK3111N3@3	EU2B-YSK3211N3@3	EU2B-YSK3311N3@3	
NO	3			٠					
NO	2	•		•	EU2B-YSK311N4@3	EU2B-YSK3111N4@3	EU2B-YSK3211N4@3	EU2B-YSK3311N4@3	
NC	3								
NO	1	•							
NO	2	•		•	EU2B-YSK330@3	EU2B-YSK3130@3	EU2B-YSK3230@3	EU2B-YSK3330@3	
NO	3			•					
NC	1				LUSD VCK303 @@		LIND ACKNON	LIND ACKNODO	
NC NC	2	_			EU2B-YSK303@3	EU2B-YSK3103@3	EU2B-YSK3203@3	EU2B-YSK3303@3	
NO	1								144g
NC	2	•	•		EU2B-YSK321N1@3	EU2B-YSK3121N1@3	EU2B-YSK3221N1@3	EU2B-YSK3321N1@3	
NO	3			•					
NC	1								
NO	2	•		•	EU2B-YSK312N1@3	EU2B-YSK3112N1@3	EU2B-YSK3212N1@3	EU2B-YSK3312N1@3	
NC	3								

Key is removable in all maintained positions. Specify key removal position in place of (3) in the part number. See table.

Specify a terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal).



The key can be released in any maintained position.

# **③ Key Removable Option Codes (3-Position)**


Code	Description
А	Key removable in any position
В	Key removable in left and center positions
С	Key removable in center and right positions
D	Key removable in center position
Е	Key removable in left and right positions
G	Key removable in left position
Н	Key removable in right position)

-11

#### Meters



# Part Number Structure - AC Ammeter




Note: Use only when interpreting part numbers. Do not use for developing part numbers.

#### Weight Input Part Number Description (approx.) EU2B-YM53A5④ Capacity: 5A Expansion scale: x3 EU2B-YM53A10@ Capacity:10/5A Expansion scale: x3 EU2B-YM13A10④ Capacity:10/1A Expansion scale: x3 EU2B-YM53A15④ Capacity:15/5A Expansion scale: x3 EU2B-YM13A15@ Capacity:15/1A Expansion scale: x3 EU2B-YM13A20④ Capacity:20/1A Expansion scale: x3 AC input meter EU2B-YM53A30④ Capacity:30/5A Expansion scale: x3 (ammeter) EU2B-YM13A304 Capacity:30/1A Expansion scale: x3 EU2B-YM53A50@ Capacity:50/5A Expansion scale: x3 EU2B-YM53A60④ Capacity:60/5A Expansion scale: x3 270g EU2B-YM53A75④ Capacity:75/5A Expansion scale: x3 EU2B-YM53A100④ Capacity:100/5A Expansion scale: x3 EU2B-YM53A150④ Capacity:150/5A Expansion scale: x3 EU2B-YM010VD@-PER 0-10V DC Input Scale: 0 to 100% EU2B-YM010VD@-60HZ 0-10V DC Input Scale: 0 to 60Hz EU2B-YM001MD@-PER 0-1mADC Input Scale: 0 to 100% DC input meter EU2B-YM001MD@-60HZ 0-1mADC Input Scale: 0 to 60Hz EU2B-YM001MD@-80HZ 0-1mADC Input Scale: 0 to 80Hz EU2B-YM420MD@-PER 4-20mA DC Input Scale: 0 to 100% EU2B-YM420MD@-60HZ 4-20mA DC Input Scale: 0 to 60Hz

Specify a terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

#### Part Number Structure - DC Ammeter or Voltmeter EU2B - YM 010 VD F-PER-R



F : Finger-safe terminal (IP20)

C : Exposed screw terminal

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Set pointer

-PER : 0~100%

-60HZ : 0~60Hz

-80HZ : 0~80Hz

blank : non -R : with set pointer


Specification of scale

# **DIMENSIONS**

All dimensions in mm

#### Pushbuttons

Shown with finger-safe contacts





24.5

19.3

# **Pilot Lights**

Shown with finger-safe contacts





67.7


20.3




(panel thickness) 67.7


Shown with finger-safe contacts


13<u>.3</u>













# **Selector Switches**


Shown with finger-safe contacts






## **Key Selector Switch**

Shown with finger-safe contacts



#### **Mounting Hole Dimensions** Panel thickness: 1.0 to 4.5 mm.

\*Note: The meter can be mounted on the top mounting holes of a standard 50mm mounting centers. The meter can be mounted on any mounting hole with a 70mm or larger mounting center.




# ACCESSORIES

All dimensions in mm

#### Nameplates

Used for pilot light, pushbutton, selector switch, and key selector switch.




#### Nameplate Inserts


Appearance	Legend	Part Number
	Blank	EU9Z-NP0
HAND OFF AUTO	ON	EU9Z-NP1
HAND OFF AUTO	OFF	EU9Z-NP2
	START	EU9Z-NP3
ON	STOP	EU9Z-NP4
	OFF-ON	EU9Z-NP31
OFF	HAND-AUTO	EU9Z-NP35
	HAND-OFF-AUTO	EU9Z-NP53

Material: Aluminum

#### Installing the Insert to the Nameplate



Removing the Insert from the Nameplate




To remove the Insert, insert a flat screwdriver between the Insert and Nameplate.

#### **Rubber Boots**

Appearance	Description/Usage	Part Number
For Flush Pushbuttons	Not for use with name plate	EU9Z-DB1
For Flush Pushbuttons	For use with name plate	EU9Z-DB1N
For Extended Pushbuttons	Not for use with name plate	EU9Z-DB2
For Extended Pushbuttons	For use with name plate	EU9Z-DB2N

#### **Emergency Stop Switch Nameplate Stickers**




Material: yellow vinyl Legend: black

#### **Padlock Cover**

EU2B-YB2 extended pushbutton: to maintain latched status


EU2B-YB1 flush pushbutton/EU2B-YSK key selector switch: to prevent operation



Material: Stainless Steel

## **Emergency Stop Switch Padlock Cover**


Used with EU2B-YBV emergency stop switch to maintain the switch in the latched status.



Coating: yellow Material: Stainless Steel

#### **Mounting Hole Plug**

Used to plug unused mounting holes (ø30.5) on the mounting panel.



-

#### Buttons

Appearance	Style	Part Number	Button Color Code
	Flush	HW1A-B1①	Specify a color code in place of ①
	Extended	HW1A-B2①	in the Ordering Number. R : red G : green B : black Y : yellow
	ø40 Mushroom	HW1A-B4①	W white S : blue

Material: Polyacetal

#### Lenses

Appearance	Lens Color	Part Number
	Red	EU9Z-LR
	Green	EU9Z-LG
	Amber	EU9Z-LA
	Yellow	EU9Z-LY
	White	EU9Z-LW
	Blue	EU9Z-LS

Material: AS resin (gasket supplied)

# **OPERATING INSTRUCTIONS**


#### Wiring

#### **Applicable Wires**

Stranded wire: 1.5 to 2.5 mm<sup>2</sup>, solid wire: ø1.2 to ø1.6 mm (AWG16 to 14) Note: Do not connect more than 2 wires to the same terminal.

#### Applicable crimping terminal

Ring and spade terminals cannot be used with IP20 finger-safe terminal blocks. When connecting 2 ferrules to the EU2B control unit, use ferrules without insulating sheath.



Recommended crimping terminal (WAGO) Ferrule with insulating sheath: 216-204 Ferrule without insulating sheath: 216-104 Crimping plier: 206-204

#### **Recommended Tightening Torque**

EU2B control units (M3.5): 1.0 to 1.3  $N{\cdot}m$ 

#### **LED Lamps**




Operating	Curre	nt Draw	Part	Illumination Color Code	Base
Voltage	AC	DC	Number		Dase
6V AC/ DC±10%	8mA	7mA (A, R, W) 5.5mA (G, PW, S)	LSTD-6①	Specify a color code in place of ① in the part number	
12V AC/ DC±10%	11mA	10mA	LSTD-1①	R : red G : green A : amber PW : white S : blue Use a white (PW) LED with	BA9S/13
24V AC/ DC±10%	11mA	10mA	LSTD-2①	yellow (Y) lens.	

#### Warning

Incorrect wiring may cause fire hazard. Observe the following conditions.


- Be sure to install an insulating sheath on the crimping terminal or the crimping terminal with insulation.
- When connecting solid wires or stranded wires directly, strip the insulation, mentioned below, and insert the wire all the way in.
  - EU2B Control units: 8.6 mm maximum
  - Crimping terminal: 8 to 9 mm
- When using stranded wires, make sure that there are no wire whiskers.
- Make sure that the spade crimping terminals and ferrules are inserted all the way in.

Insulating tube (covered)




#### Removing and Installing the Contact Unit / Lamp Unit

To remove the contact unit or the lamp unit from the operator, pull the protruding yellow part of the locking lever outwards as shown in the figure below using a screwdriver, and turn it to the left. The contact unit or lamp unit can be removed.



When the contact unit is removed from the emergency stop switch operator, the NO contact closes and the NC contact opens.

Do not turn the locking lever when the contact unit is removed from the operator (the red indicator is protruding out. See the figure below) or the switch can be damaged.



#### Panel mounting for the operator, lens unit and meter

Remove the locking ring from the operator and check that the rubber gasket is in place. Insert the operator from the panel front into the panel hole. Place the projection on the operator with TOP marking upward and the recess on the mounting panel in the same direction. (The meter has no projection.)

Tighten the locking ring using ring wrench XN9Z-T1 to a torque of 2.5 Nm. When using a nameplate or padlocking cover, install it between the operator and panel. Make sure that the groove of the namplate or padlocking cover and the projection on the TOP marking of the operator are in the same direction.


Note: The locking ring for emergency stop switches and meter is metallic. The meter can't mount the nameplate or podlocking cover.

#### Installing the contact unit and lamp unit

To install the contact unit, place the TOP marking on the operator and the TOP marking on the contact block adapter in the same direction, and then attach the contact unit to the operator. Then turn the locking lever to the right. Follow the same procedure when installing the lamp unit.


When installing the lamp unit, check that the inner lens is not loose.

The contact block adapters for emergency stop switches cannot be used for the pushbutton, selector and key selector switches.



#### **Removing the Contact Block**

To remove the contact block, insert a flat screwdriver under the latch of the contact block adaptor and disengage the latch as shown in the figure below.



#### **Installing the Contact block**

When installing the contact block after maintenance or wiring, make sure that the contact configuration is correct. Installing the contact block in the incorrect position or incomplete installation may cause malfunction of the switch.

Remove the contact block from the operator before installing the contact block to the contact block adaptor. Also make sure that the contact block is correctly installed to the contact block adaptor before attaching the operator. Do not install the contact block adaptor with the operator attached. Otherwise, malfunction may result.

#### Accessories

#### **Padlock Cover**

The following padlocks and hasps can be used.

(Padlock Size)	а	b	С
Flush/extended pushbutton/key selector switch	ø3.5 to 7.0 mm	15 mm min.	70 mm max.
Emergency Stop Switch	ø5.5 to 7.0 mm	—	-

#### **Recommended Hasp**

Manufacturer	Part No.
Panduit	PSL-1, PSL-1A, PSL-1.5, PSL-1.5A, PSL-HD1
Master Lock	420, 421

Padlock and hasp are available in various shapes and sizes. Make sure that they do not interfere with the control units. Note: Not supplied by IDEC.

Keep the total weight of padlock and hasp under 1500g max, otherwise the switch may malfunction or result in failure. No vibration should be applied when padlock or hasp are installed. When padlock or hasp are disfigured, stop usage immediately.

Ensure that no shock or electric sparks are generated.

When using the plate lock padlock cover with the extended pushbutton, the switch contact may turn on/off when the cover is being installed. Ensure to provide functional safety measure to prevent unexpected startup.

When using the padlock cover on the safety-related part of the control system, observe safety standards and regulations of the relevant country or region. Also be sure to perform risk assessment before operation.


#### Installing EU9Z-PC Padlock Cover

(Flush/extended pushbtton/key selector switch)

EU9Z-PC can be installed in the following two ways.


Remove the cover in the reverse step of installing the cover. Do not install or remove the cover forcefully, or it will cause failure.

[Installation A]




#### [Installation B]

This method is effective when the neighboring control unit interferes when installing in method A.



#### Installing EU9Z-DB Rubber Boots

To install the rubber boot on flush and extended pushbuttons, place the rubber boot on the cap and push the rubber boot holder straight. The notches around the rubber boot must show evenly.



Push the rubber boot holder further around on the two notches on the holder so that the holder fits the button completely

Make sure that the rubber boot and rubber boot holder are installed straight.

On Nameplate Types, the EU2B and the rubber boot holder must be aligned so that when installed, the anti-rotation projection on the EU2B comes to the center of the groove on the holder. Make sure that the rubber boot is installed completely, otherwise water droplets might enter the rubber boot, but no water will enter the control box.



To remove the rubber boot from the flush and extended pushbuttons, gently insert the slotted screwdriver (0.5t x 4w or below) inside a notch on the rubber boot holder and tilt to the direction shown by the arrow O. To prevent damage, do not apply excessive force to the EU2B when removing the rubber boot.



#### **Maintenance and Inspection**

EU2B switches should be installed in an appropriate control box.

#### Maintenance and Inspection Method

Perform daily or periodical maintenance and inspection for items such as damage and temperature rise of the EU2B switches listed in the Maintenance and Inspection table below.

#### **Maintenance and Inspection**

Inspection Items	Inspection Method	Inspections	Measures
Enclosure base	Visual	No rusting No damages	Cleaning Rust-resistant treat- ment
Tightening bolt, screws	Visual, tactile	No loosening No rusting	Tightening Cleaning
Packings	Visual	No cracks No apparent deforma- tion	Replacement
Connecting parts	Visual, tactile	No loosening of screws No dirt on insulation materials	Tightening Cleaning
Temperature rise	Thermometer, tactile	Surface temperature 80°C max.	Investigate the cause

#### Disposal

Observe laws and regulations set by each country concerning refuse disposal.

#### Safety Precautions

Use EU2B switches that are applicable for use in hazardous areas (potentially explosive atmosphere where explosive gas or vapor may exist), otherwise explosion or fire hazard may result.

- EU2B switches can be installed only in zones 1 and 2. Do not use in zone 0.
- Turn power off to the EU2B switches before installation, removal, wiring, or maintenance, otherwise explosion, fire hazard, or electric shock may result.
- Do not disassemble, repair, or modify, otherwise damage or accident may result.
- Do not use damaged EU2B switches, otherwise damage or accident may result.
- When connecting external devices, make sure that each cable is connected to the correct terminal, otherwise electric shock, fire hazard, or explosion may result.
- Use wires of a proper size to meet voltage and current requirements. Incorrect wiring may
  cause abnormal temperature rise and lead to fire hazard and explosion.
- Connect the grounding terminal to a proper ground, otherwise electric shock, fire hazard, or explosion may result.
- Operate the EU2B switches at the rated current and voltage specified in this catalog, otherwise short-circuiting, fire hazard, or explosion may result.
- Stop operation immediately if abnormal operation occurs. Otherwise, a secondary accident may occur.



IDEC Corporation • 1175 Elko Drive • Sunnyvale, CA 94089 • 800-262-IDEC (4332) • Fax: 408-745-5258 • www.IDEC.com/usa ©2015 IDEC Corporation. All Rights Reserved. EU9Y-DS100-1a pdf only